

Addendum No. 1

Project: Residency Program Renovation

Baptist Hospital

Date: <u>3-16-22</u>

All bidders are herewith notified of the following additions, deletions, changes or clarifications to the drawings dated 3/10/22 and shall be acknowledged as received on the proposal.

- 1. See attached Pre-Bid sign in sheet.
- 2. An ICRA will be issued to the successful contractor prior to the start of construction. Contractor will be required to provide a drywall constructed barrier Ante-rooms with sealed swinging door at the entrances to each area under construction, along with HEPA filtration within the space and walk-off mats at all exits into the Hospital from the construction sites.

3. Refer to SK-A1

- a. Contractor shall be responsible for removing and disposing of the existing sliding file system and raised wood subfloor.
- b. Existing partition separating the file system and the remainder of the Classroom space shall be removed, leaving a finished drywall header to separate the two ceilings.
- c. Existing door in North wall of Classroom 1Z33 into adjacent Work Stations 1Z26 shall be removed and opening infilled with drywall, and each side of the partition refinished and repainted.
- d. All existing millwork within the Classroom and Lounge areas shall be removed and discarded.

- e. Contractor has option to remove the existing ceilings in Classroom 1Z33 and Lounge 1Z34, and replacing with new fire rated grid and ceiling tiles to facilitate the installation of the new ductwork and accordion partition, or remove ceilings in sections as may be required and reinstall after the above ceiling work is completed. If contractor chooses to remove and replace the ceiling, then the header noted in item 3b can be eliminated. Note that the ceiling is a 2-hr fire rated assembly, and all diffusers must have fire dampers, and all lights must be fire tented with UL approved assemblies.
- 4. Owner will test all areas for hazardous materials prior to the start of work. For bidding purposes, contractor shall assume no hazardous materials are present, and shall include all demolition in the bid. Should hazardous materials be located, Owner will have the materials abated, and the demolition scope of work for the affected areas will be removed from the contract by change order.
- 5. The weight of the accordion door is 2.7 lbs per sf. Total weight is 462 pounds, with header supporting 24.3 pounds per linear foot. Header framing is identified on sheet A100. Header detail 3/A300 shall project 2 inches below the ceiling.
- 6. If tearing into the walls of Men's Toilet 1Z02 is required by the plumbing contractor to tie in the sanitary drain line from SK-1, contractor shall include the cost to patch back the walls.

End of Addendum # 1



Date: 3/16/22



350 Pine Street Suite 720 Edison Plaza

> Beaumont, TX 77701 Phone: 409.866.7196

> > Fax: 409.866.1745

PRE-BID ATTENDEES' LIST

Project Number: 21070

Project Name: Residency Program Renovation 1st Floor
Project Owner: Baptist Hospitals of Southeast Texas
Project Address: 3080 College Street, Beaumont, TX 77701
Date / Time: Tuesday, March 15, 2022 / 10:00 AM

Location: Jeromy Jenkin's Office

NAME COMPANY EMAIL

NAME	COMPANY	LIVIPALL
GEORGE Guy	PRECISION Built,	gdguy@PRECISION-BUILT, COM,
Chuck Mulhollow	Plby Spec	PSIC Metho How & Ad Com
Tedd Herring	Custom Flooring	TELLHORING TO @GMA, 1. COM
Brian Shipp	SETEX CONSTRUCTION	Briows@ servery gracio
Veromy V	Baplost.	
Micaela Marno	BHSET	Kevin me czigloboli com
Rodney Jenkins	Metal Ind	Possjenkins @ ptt. com
Taylor Davis	Sirfaces	FAMILY. SUYFAUS BOUNOUS. COn
Todd Anderson	All Phuse Builda	Todd. All Physe a ynhus. ce



